

NORTHERN DISTRICT DAILY REPORT

MONO BASIN

Rush Cr @ Dam: 11 Lee Vining Creek: Above 17 (Spill: 16, Conduit: 0)
 West Portal : 50 Mono Lake Elev: 6381.07; (USGS Datum) (Read on: 12/8
 C Ranch Hi/Lo: 53/14 Precip(Day/Month): 0.00/0.01
 Parker Cr Abv: 3 Below: 3 Walker Cr Abv: 2 Below: 2
 Grant Lake Spill: 0
 (*) **Grant Lake El:** 7109.9 Outflow: 78 24hr AF Total: 157
 (7130.0 HW)AF: 27125 Diff AF: -143 Grant Lake Toe Drain: 0.19

LONG VALLEY

East Portal : 62 Below East Portal: 111
 (*) **L V Resv Elev:** 6765.7 Outflow: 32 24hr AF Total: 64
 (6781.5 HW)AF: 111309 Diff AF: 390
 L Vally Hi/Lo: 51/9 Precip(Day/Month):0.00/0.04
 ORG Main Weir: 3.40 Tunnel Drain: 0.21 Toe Drain: 0.44
 Rock Crk Div : 0

NORTH OWENS

RC@OR Cur/Ave: 39/39 Gorge: UG Cur/Avg: 45/45 MG Cur/Avg: 0/0
 (*) **P V Resv Elev:** 4388.0 Outflow: 91 24hr AF Total: 178
 (4390.0 HW)AF: 2792 Diff AF: -6
 Bishop Hi/Lo: 64/21 Precip(Day/Month): 0.00/0.00
 B C @ Plant 6: 59(avg) O R Below BP Cr: 172 Fish Sprg @ RR Brdg: 23
 BP Pwr House : 64/32 Precip(Day/Month): 0.00/0.00 BP Cr Cur/Peak: 9/10

WELLS

	<u>North Wells</u>		<u>South Wells</u>		<u>* Total *</u>	
Aqueduct	(5)	29.8	(8)	45.8	(13)	75.6 On: W330,
Domestic	(3)	4.6	(3)	1.9	(6)	6.5
Enhc./Mitig.	(0)	0.0	(3)	5.4	(3)	5.4 Off: W375,
* Total *	(8)	34.4	(14)	53.1	(22)	87.5

SOUTH OWENS

(*) **Tin Resv Elev:** 3861.6 Outflow: 151 24hr AF Total: 303
 (3866.0 HW)AF: 2420 Diff AF: 38
 Tin Res Hi/Lo: 63/25 Precip(Day/Month): 0.00/0.00

LAA Intake Precip(Day/Month): 0.00/0.00
 Indep Hi/Lo: 59/31 Precip(Day/Month): 0.00/0.00
 Alab Gt Hi/Lo: 67/32 Precip(Day/Month): 0.00/0.00
 Cotw Gt Hi/Lo: 58/28 Precip(Day/Month): 0.00/0.00
 Blckrck Spill: 0.0 Thibaut Spillgates: 0.2 Lone Pine Creek: 2
 Alab Gates GA: 5.46 Flow: 178
 Cottw Gt Gage: 7.76 Flow: 225 Creek: 0 Power Plant: 5
LORP(inflows): Intake 43, Blackrock 1.1, Goose 0.0, Billy 1.1, Locust 0.0,
 Georges 0.0, Alabama Gates 0 **Total Inflow(cfs): 46**
 (outflows): PumpSta 45, Delta(L.G.) 7, Delta(weir) 0 **Total Outflow(cfs): 51**
 Lubkin Splgt: Flow(in/out): 11/0 AF Total(in/out): 32/0 net AF: -32
 Cartago Splgt: Flow(in/out): 0/21 AF Total(in/out): 0/15 net AF: 15
 Owens Lk Use : (net avg cfs) PumpSta 44.8, Lubkin -16, Cartago 8 **Total: 36**

(*) **N Haiwee Elev:** 3756.8
 (3757.5 HW)AF: 9647 Diff AF: -29
 (*) **S Haiwee Elev:** 3724.7
 (3742.0 HW)AF: 13888 Diff AF: 6
 S Haiwe Hi/Lo: 63/30 Precip(Day/Month): 0.00/0.00
 Hai Pwr Plant: 0 24hr AF Total: 0
 LAA #2 S Haiw: 200 24hr AF Total: 396