

MONO BASIN	Rush Cr @ Dam:	10	Lee Vining Creek: Above 19 (Spill: 16, Conduit: 3)			
	West Portal :	0	Mono Lake Elev: 6379.29; (USGS Datum) (Read on: 2/8)			
	C Ranch Hi/Lo:	37/-3	Precip(Day/Month): 0.00/0.28			
	Parker Cr Abv:	3	Below: 3	Walker Cr Abv: 4	Below: 4	
		Grant Lake Spill: 0				
	(*) Grant Lake El:	7101.8	Outflow: 27	24hr AF Total: 53		
	(7130.0 HW)AF:	20295	Diff AF: 8	Grant Lake Toe Drain: 0.00		
LONG VALLEY	East Portal :	13	Below East Portal:	52		
	(*) L V Resv Elev:	6770.5	Outflow: 147	24hr AF Total: 285		
		(6781.5 HW)AF:	131045	Diff AF: 129		
	L Vally Hi/Lo:	38/-12	Precip(Day/Month):0.00/0.25			
	ORG Main Weir:	3.20	Tunnel Drain: 0.17	Toe Drain: 0.50		
	Rock Crk Div :	0				
NORTH OWENS	RC@OR Cur/Ave:	40/40	Gorge: UG Cur/Avg:	40/40 MG Cur/Avg: 0/0		
	(*) P V Resv Elev:	4398.9	Outflow: 200	24hr AF Total: 396		
		(4390.0 HW)AF:	3972	Diff AF: 4		
	Bishop Hi/Lo:	69/28	Precip(Day/Month): 0.00/0.12			
	B C @ Plant 6:	34(avg)	O R Below BP Cr: 224	Fish Sprg @ RR Brdg: 29		
	BP Pwr House :	65/31	Precip(Day/Month): 0.00/0.17 BP Cr Cur/Peak: 9/10			
WELLS		<u>North Wells</u>	<u>South Wells</u>	<u>* Total *</u>		
	Aqueduct	(2) 31.5	(4) 17.8	(6) 49.3	On:	
	Domestic	(4) 4.9	(3) 1.9	(7) 6.8		
	Enhc./Mitig.	(0) 0.0	(1) 0.3	(1) 0.3	Off:	
	* Total *	(6) 36.4	(8) 20.0	(14) 56.4		
SOUTH OWENS	(*) Tin Resv Elev:	3861.5	Outflow: 199	24hr AF Total: 394		
		(3866.0 HW)AF:	2414	Diff AF: 13		
	Tin Res Hi/Lo:	69/31	Precip(Day/Month): 0.00/0.06			
	LAA Intake	Precip(Day/Month): 0.00/0.04				
	Indep Hi/Lo:	65/34	Precip(Day/Month): 0.00/0.00			
	Alab Gt Hi/Lo:	67/33	Precip(Day/Month): 0.00/0.00			
	Cotw Gt Hi/Lo:	61/33	Precip(Day/Month): 0.00/0.00			
	Blckrck Spill:	0.0	Thibaut Spillgates: 2.6	Lone Pine Creek: 4		
	Alab Gates GA:	5.65	Flow: 203			
	Cottw Gt Gage:	6.44	Flow: 260	Creek: 1	Power Plant: 7	
	LORP(inflows):	Intake 41, Blackrock 1.6, Goose 0.0, Billy 3.2, Locust 0.0,				
		Georges 0.6, Alabama Gates 0				
		Total Inflow(cfs): 50				
	(outflows):	PumpSta 48, Delta(L.G.) 6, Delta(weir) 5				
		Total Outflow(cfs): 59				
	Lubkin Splgt:	Flow(in/out): 19/0 AF Total(in/out): 33/0 net AF: -33				
	Cartago Splgt:	Flow(in/out): 0/4 AF Total(in/out): 7/5 net AF: -2				
Owens Lk Use :	(net avg cfs) PumpSta 47.9, Lubkin -17, Cartago -1					
	Total: 30					
(*) N Haiwee Elev:	3757.0					
	(3757.5 HW)AF:	9744	Diff AF: 80			
(*) S Haiwee Elev:	3731.6					
	(3742.0 HW)AF:	18897	Diff AF: -604			
S Haiwe Hi/Lo:	64/32	Precip(Day/Month): 0.00/0.00				
Hai Pwr Plant:	419	24hr AF Total: 793				
LAA #2 S Haiw:	113	24hr AF Total: 220				
SOUTHERN DISTRICT	BOUQUET RELEASE	INST: 1.0 CFS	PREV DAY: 1.0 CFS			