

MONO BASIN

Rush Cr @ Dam: 79 Lee Vining Creek: Above 81 (Spill: 81, Conduit: 0.4)
 West Portal : 0 Mono Lake Elev: 6383.28; (USGS Datum) (Read on: 8/30)
 C Ranch Hi/Lo: 83/33 Precip(Day/Month): 0.00/0.13
 Parker Cr Abv: 22 Below: 22 Walker Cr Abv: 10 Below: 10
 Grant Lake Spill: 0
 (*) **Grant Lake El:** 7125.8 Outflow: 160 24hr AF Total: 323
 (7130.0 HW)AF: 42670 Diff AF: -63 Grant Lake Toe Drain: 0.12

LONG VALLEY

East Portal : 12 Below East Portal: 75
 (*) **L V Resv Elev:** 6779.7 Outflow: 274 24hr AF Total: 916
 (6781.5 HW)AF: 173826 Diff AF: -255
 L Vally Hi/Lo: 86/36 Precip(Day/Month):0.00/0.08
 ORG Main Weir: 4.20 Tunnel Drain: 0.19 Toe Drain: 0.54
 Rock Crk Div : 6

NORTH OWENS

RC@OR Cur/Ave: 71/69 Gorge: UG Cur/Avg: 75/74 MG Cur/Avg: 0/0
 (*) **P V Resv Elev:** 4380.8 Outflow: 410 24hr AF Total: 785
 (4390.0 HW)AF: 2123 Diff AF: 323
 Bishop Hi/Lo: 93/47 Precip(Day/Month): 0.00/0.00
 B C @ Plant 6: 172(avg) O R Below BP Cr: 398 Fish Sprg @ RR Brdg: 35
 BP Pwr House : 91/54 Precip(Day/Month): 0.00/0.03 BP Cr Cur/Peak: 77/79

WELLS

| | North Wells | | South Wells | | * Total * | |
|--------------|-------------|------|-------------|------|-----------|----------|
| Aqueduct | (4) | 37.9 | (5) | 38.5 | (9) | 76.4 On: |
| Domestic | (4) | 4.9 | (3) | 1.9 | (7) | 6.8 |
| Enhc./Mitig. | (0) | 0.0 | (3) | 4.5 | (3) | 4.5 Off: |
| * Total * | (8) | 42.8 | (11) | 44.9 | (19) | 87.7 |

SOUTH OWENS

(*) **Tin Resv Elev:** 3864.0 Outflow: 498 24hr AF Total: 973
 (3866.0 HW)AF: 4340 Diff AF: -246
 Tin Res Hi/Lo: 93/50 Precip(Day/Month): 0.00/0.00

LAA Intake Precip(Day/Month): 0.00/0.00
 Indep Hi/Lo: 91/55 Precip(Day/Month): 0.00/0.00
 Alab Gt Hi/Lo: 93/56 Precip(Day/Month): 0.00/0.00
 Cotw Gt Hi/Lo: 90/61 Precip(Day/Month): 0.00/0.00
 Blckrck Spill: 0.0 Thibaut Spillgates: 0.0 Lone Pine Creek: 36
 Alab Gates GA: 8.00 Flow: 457
 Cottw Gt Gage: 9.86 Flow: 584 Creek: 36 Power Plant: 0
LORP(inflows): Intake 49, Blackrock 2.0, Goose 0.0, Billy 1.9, Locust 0.0,
 Georges 1.2, Alabama Gates 120 **Total Inflow(cfs): 176**
 (outflows): PumpSta 46, Delta(L.G.) 0, Delta(weir) 113 **Total Outflow(cfs): 159**
 Lubkin Splgt: Flow(in/out): 47/0 AF Total(in/out): 96/0 net AF: -96
 Cartago Splgt: Flow(in/out): 0/0 AF Total(in/out): 0/0 net AF: 0
 Owens Lk Use : (net avg cfs) PumpSta 45.9, Lubkin -48, Cartago 0 **Total: -2**

(*) **N Haiwee Elev:** 3757.0
 (3757.5 HW)AF: 9744 Diff AF: -23
 (*) **S Haiwee Elev:** 3744.9
 (3742.0 HW)AF: 30523 Diff AF: 305
 S Haiwe Hi/Lo: 91/61 Precip(Day/Month): 0.00/0.00
 Hai Pwr Plant: 408 24hr AF Total: 796
 LAA #2 S Haiw: 80 24hr AF Total: 119

SOUTHERN DISTRICT

BOUQUET RELEASE INST: 2.5 CFS PREV DAY: 2.5 CFS

